

APPENDIX 8A: NOISE PERCEPTION AND TERMINOLOGY

- 8A.0.1 Between the quietest audible sound and loudest tolerable sound there is a million to one ratio in sound pressure (measured in pascals, Pa). Because of this wide range a noise levels scale based on logarithms is used in noise measurement call the decibel (dB) scale. Audibility of sound covers a range of approximately 0 to 140 dB.
- 8A.0.2 The human ear system does not respond uniformly to sound across the detectable frequency range and consequently instrumentation used to measure noise is weighted to represent the performance of the ear. This is known as the 'A weighting' and annotated as dB(A) or LpA dB. Table 8A.1 below lists the sound pressure level in dB(A) for common situations.

Table 8A.1: Sound pressure levels for a range of situations

NOISE LEVEL DB(A)	TYPICAL SITUATION
0	Threshold of hearing
30	Rural area at night, still air
40	Public library, refrigerator humming at 2 m
50	Quiet office, no machinery. Boiling kettle at 0.5 m
60	Normal conversation
70	Telephone ringing at 2 m. Vacuum cleaner at 3 m
80	General factory noise levels
100	Pneumatic drill at 5 m
120	Discotheque – 1 m in front of loudspeaker
140	Threshold of pain

- 8A.0.3 The noise level at a measurement point is rarely steady, even in rural areas, and varies over a range dependent upon the effects of local noise sources. Close to a busy road, the noise level may vary over a range of 5 dB(A), whereas in a suburban area this may increase up to 40 dB(A) and more due to the multitude of noise sources in such areas (cars, dogs, aircraft etc.) and their variable operation. Furthermore, the range of night time noise levels will often be smaller and the levels significantly reduced compared to daytime levels.

8A.1 Background Noise Levels

- 8A.1.1 A parameter that is widely accepted as reflecting human perception of the ambient noise is the background noise level, L90, this is usually A weighted and can be displayed as L90 dB(A) or LA90 (dB). This is the noise level exceeded for 90% of the measurement period and generally reflects the noise level in the lulls between individual noise events. Over a one hour period, the LA90 will be the noise level exceeded for 54 minutes.

8A.2 Ambient or Activity Noise Levels

- 8A.2.1 The equivalent continuous A-weighted sound pressure level, LAeq (or Leq dB(A)) is the single number that represents the total sound energy measured over that period. LAeq is the sound level of a notionally steady sound having the same energy as a fluctuating sound over a specified measurement period. It is commonly used to express the energy level from individual sources that vary in level over their operational cycle.

8A.3 Noise Changes

8A.3.1 Human subjects are generally only capable of noticing changes in noise levels of no less than 3 dB(A). It is generally accepted that a change of 10 dB(A) in an overall, steady noise level is perceived to the human ear as a doubling (or halving) of the noise level. (These findings do not necessarily apply to transient or non-steady noise sources such as changes in noise due to changes in road traffic flow, or intermittent noise sources).

8A.4 Sound Power

8A.4.1 Sound power is the rate per unit time at which airborne sound energy is radiated by a source. It is expressed in watts (W). Sound power level or acoustic power level is a logarithmic measure of the sound power in comparison to the reference level of 1 pW (picowatt). The sound power level is given the letter "Lw" or SWL. It is not the same thing as sound pressure (Lp). Any Lp value is dependent of the distance from the noise source and the environment in which it was measured. Lw values are preferred for noise prediction purposes as their value is independent of distance or environment. There are recognised formulas for converting Lw to Lp.

8A.4.2 A-weighted sound power levels are usually denoted LwA (dB) or sometimes Lw (dBA) or SWL (dBA).

8A.5 Sound Reduction Index

8A.5.1 The sound insulation properties of a material are described by the term 'sound reduction index' (R) i.e. it is a measure of the reduction in the amount of sound transmitted through a material. The higher the sound reduction index the greater the attenuation provided by the material. The value of R depends on a range of factors, in particular the mass of the material, the nature of the material, and the frequency of the sound. The R values for individual octave bands can be combined into an overall single figure, the weighted sound reduction index Rw.

8A.6 Internal Noise Levels

8A.6.1 In an enclosed space such as an individual room, or a building, the noise from a source cannot propagate in the same way as outdoors because the propagation of the sound is obstructed by the boundaries (walls, ceiling and floor) of the building. These surfaces together with the contents of the building reflect a proportion of the sound back inside the building or room, the amount depending on the absorption coefficient of the various surfaces. Therefore the overall noise level at a position within the building is a combination of the sound received directly from the source (the direct sound field) and the sound received from reflections from the internal surfaces (the reverberant sound field). The more absorptive the surfaces in a building the less sound is reflected and the lower the contribution of the reverberant sound field to the overall noise level.

8A.7 Frequency Spectrum


8A.7.1 Frequency is the rate at which the air particles vibrate. The more rapid the vibrations, the higher the frequency and perceived pitch. Frequency is measured in Hertz (Hz).

8A.7.2 A young person with average hearing can generally detect sounds in the range 20 Hz to 20,000 Hz (20 kHz). Figure 9A.1 below illustrates the range of frequencies, for example, the lowest note on a full scale piano, 'A', has a fundamental at 28 Hz, and the highest, 'G', a fundamental at 4186 Hz (there will be higher order harmonics). Human speech is predominantly in the range 250 Hz - 3000 Hz.

8A.7.3 The musical term 'octave' is the interval between the first and eighth note in a scale and represents a doubling of frequency. A series of octave and one-third octave bands have been derived, as shown on Figure A7.1.1 and these are commonly used in noise

measurements where it is necessary to describe not only the level of the source noise but also the frequency content. The frequency content of a noise source can be useful for identifying acoustic features such as a whine, hiss or screech.

Figure 8A.1: Octave and 1/3 octave frequency bands



APPENDIX 8B: CONSULTATION WITH NELC ENVIRONMENTAL HEALTH OFFICER

From: Vicky Thompson (NELC) [<mailto:Vicky.Thompson@nelincs.gov.uk>]
Sent: 13 July 2018 15:55
To: Sargent, Ruth
Subject: RE: CONFIDENTIAL: Proposed Energy Centre, Stallingborough - Noise Assessment

Dear Ruth,

Thank you for providing information on the proposed methodology for the noise assessment in relation to the Energy Centre, Stallingborough planning application.

Regarding Baseline noise monitoring I can confirm I am happy with the methodology stated along with the locations.

Regarding the Operational Noise and Vibration section I agree to the BS4142: 2014 assessment method and we ask for the rating level to be no more than 5dB above background so the proposed is acceptable.
 Will you be providing any information for 1/3 octave levels for the plant and is there to be any comparison against BS8237 criteria (in particular for LAeqmax)?

Happy with the rest of the proposed methods including the construction noise and vibration section.

Regards

Vicky Thompson, Technical Officer, Pollution Control, North East Lincolnshire Council
 Municipal Offices, Town Hall Square, Grimsby, DN31 1HU
 [REDACTED] | vicky.thompson@nelincs.gov.uk | www.nelincs.gov.uk



From: Sargent, Ruth <ruth.sargent@aeom.com>
Sent: 13 July 2018 11:51
To: Vicky Thompson (NELC) <Vicky.Thompson@nelincs.gov.uk>
Subject: CONFIDENTIAL: Proposed Energy Centre, Stallingborough - Noise Assessment
Importance: High

Good morning Vicky,

Your contact details have been provided by Cheryl Jarvis in the planning department. I hope that you are able to respond to my queries. **PLEASE NOTE THAT THE INFORMATION PROVIDED BELOW IS CONFIDENTIAL AT THIS TIME.**

AECOM has been commissioned to undertake a noise assessment for a proposed new Energy Centre, for the generation of electricity by combustion of refuse derived fuel (RDF), at land off South Marsh Road, Stallingborough, located adjacent to the South Humber Bank Power Station.

The purpose of this email is to inform you of our proposed measurement and assessment methodologies with a view to gaining your agreement to them. With regards to the measurement methodology, we would appreciate it if you could advise this is suitable as soon as possible as our clients programme requires to undertake the monitoring over the next few weeks.

Baseline noise monitoring

To understand the prevailing noise climate we proposed to undertake noise monitoring at a number of locations representative of the closest noise sensitive receptors to the proposed facility (subject to access), namely residential properties and the Special Protection Area. Please see the attached diagram – long term locations are in red, short-term are in green. Site boundary is in blue.

Long term:

- Primrose Cottage (or Cress Cottage)
- Poplar Farm
- Site boundary of existing site power station site (somewhere along the dotted line, depending on security and any other noise sources which may influence noise climate)

Short-term:

- Edge of estuary (Special Protection Area)
- Mauxhall Farm (for inclusion in the operational traffic assessment)

It is proposed that noise monitoring at the long-term locations will be undertaken over a minimum of 5 days, to include a weekend. The meters will be set to log contiguous periods of 15 minutes and measure the LAeq, LA90 and LAMax parameters.

At the short-term locations, monitoring will be undertaken for a minimum period of one hour with the meter set to log contiguous periods of 15 minutes and measure the LAeq, LA90 and LAMax parameters.

Please can you confirm that our measurement methodology is acceptable, or advise accordingly?

Operational Noise and Vibration

A noise model of the proposed Energy Centre will be produced based on the available information on the equipment to be installed, the operational times, and the building fabric. The model will also include the noise generated by HGV movements and other on-site mobile plant. The predicted noise levels will be compared with the existing measured noise levels and an assessment of the noise impact undertaken using the methodology given in BS 4142: 2014 'Methods for rating and assessing industrial and commercial sound'. We propose that a Rating Level no greater than 5 dB above the average background noise level would be acceptable. Please can you confirm this is acceptable or advise accordingly?

Any change in road traffic noise levels as a result of the operation of the facility will be predicted using the standard methodology outlined in CRTN. The predictions will be based on baseline and with development traffic data. The significance of the impact on road traffic noise levels will be assessed based on a range of relevant guidance including the 'Design Manual for Roads and Bridges: 2011'.

The operation of this type of facility is not a source of significant ground borne vibration. Consequently, operational vibration is scoped out of the assessment.

We would be grateful if you could confirm acceptance of this assessment methodology or advise accordingly.

Construction Noise and Vibration

A construction noise and vibration assessment will be undertaken assuming typical construction activities, plant and operational times as detailed information will not be available until a contractor is appointed. Noise and vibration levels will be predicted using the methodology given in BS 5228: 2009+A1:2014 'Control of noise and vibration from construction and open sites', and the significance of noise impact assessed against the measured ambient noise levels.

Noise increases at sensitive receptors due to any construction traffic on public roads will be calculated according to the methods given in CRTN.

We would be grateful if you could consider our proposed measurement and assessment methodologies and advise as to whether they are suitable. We would also be grateful if you could forward any applicable noise policies that cover the development area.

Thanking you in anticipation.

Kind regards,

Ruth Sargent BSc(Hons) MSc MIOA
Senior Acoustic Consultant, Environment and Ground Engineering


ruth.sargent@aecom.com

AECOM
12 Regan Way, Chetwynd Business Park, Chilwell, Nottingham, NG9 6RZ
T +44 (0)115 907 7000 F +44 (0)115 907 7001
www.aecom.com

APPENDIX 8C: NOISE MONITORING

8C.1 Noise Survey Instrumentation

8C.1.1 All measurements were taken at approximately 1.2-1.5 m above ground level, and in accordance with the requirements of British Standard (BS) 7445 (BSI, 1991 and 2003). All monitoring locations were positioned at least 3.5 m from any reflecting surface, other than the ground (i.e. free-field). Details of ongoing activities and typical noise sources in the area were recorded during visits to the monitoring locations to set up and collect the measurement equipment.

8C.1.2 All SLMs used were Class 1 precision instruments. Each was programmed to log a number of parameters including L_{Aeq} , L_{A90} , L_{A10} and L_{Amax} values, in 15-minute contiguous intervals.

8C.1.3 The calibration levels were checked prior to and following all measurements. No significant drift, more than 0.2 dB, occurred. Full calibration details are available upon request.


8C.1.4 Details of the meters used in the assessment are given in Table 8C.1.

Table 8C.1: Measurement equipment


MONITORING LOCATION	MANUFACTURER	SLM MODEL	SLM SERIAL NUMBER
LT1	Rion	NL-52	01021280
LT2	Rion	NL-52	01021281
LT3	Rion	NL-52	01021278
ST1 and ST2	Rion	NL-52	01021282

8C.2 Time History Plots


Monitoring Location LT1 - Poplar Farm



Monitoring Location LT2 - Cress Cottage



Monitoring Location LT3 - Southern Site Boundary



APPENDIX 8D: CONSTRUCTION

8D.1.1 The assumed construction activities and plant are given in Table 8D.1, along with corresponding noise data.

Table 8D.1: Construction plant details

ACTIVITY	PLANT	LWA	ACTIVITY ON-TIME (%)	REFERENCE
Site Clearance	Chainsaw	114	10	BS 5228 Table D.2 no 14
	Excavator	105	50	BS 5228 Table C.2 no 2
	Loading lorries	106	20	BS 5228 Table C.2 nos. 26-28
Earthworks	Excavator	105	50	BS 5228 Table C.2 no 2
	Dumper	102	50	BS 5228 Table C.2 no 32
	Loading lorries	106	20	BS 5228 Table C.2 no.s 26-28
Drop Hammer Piling	Drop Hammer Piling Rig	122	50	BS 5228 Table C.12 average no.s 11, 13-25
	Service crane	97	50	BS 5228 Table C.3 ave no.s 28-29
	Cement mixer truck	106	50	BS 5228 Table C.4 no 32
Foundations	Excavator	102	75	BS 5228 Table C.2 ave 14-25
	Lorry mounted concrete pump	107	50	BS 5228 Table C.2 ave 26-28
	Lorry mounted concrete pump	105	50	BS 5228 Table D.7 ave 121-122
	Cement mixer truck	106	50	BS 5228 Table C.4 no 32
	Poker vibrator	97	75	BS 5228 Table C.4 no 34
Slab Construction	Lorry mounted concrete pump	107	50	BS 5228 Table C.2 ave 26-28
	Lorry mounted concrete pump	105	50	BS 5228 Table D.7 ave 121-122
	Cement mixer truck	106	50	BS 5228 Table C.4 no 32
	Poker vibrator	97	75	BS 5228 Table C.4 no 34
Building Construction	Tower crane	105	50	BS 5228 Table C.4 ave 48-49
	Generator	94	100	BS 5228 Table C.4 ave 76-84
	Electric drills	104	50	BS 5228 Table D.6 no 54
	Lorry mounted concrete pump	105	25	BS 5228 Table D.7 ave 121-122

ACTIVITY	PLANT	LWA	ACTIVITY ON-TIME (%)	REFERENCE
	Cement mixer truck	106	50	BS 5228 Table C.4 no 32
	Poker vibrator	97	75	BS 5228 Table C.4 no 34
Finishing and Fitting	Generator	94	100	BS 5228 Table C.4 ave 76-84
	Electric drills	104	50	BS 5228 Table D.6 no 54
	Asphalt spreader	104	75	BS 5228 Table C.5 ave 30-31
	Welding plant	102	50	BS 5228 Table C.3 no 31
Access Roads and Car Parks	Excavator	102	75	BS 5228 Table C.2 ave 14-25
	Dumper	109	50	BS 5228 Table C.5 no 16
	Asphalt spreader	104	75	BS 5228 Table C.5 ave 30-31
	Road roller	103	75	BS 5228 Table C.5 ave 25-28

APPENDIX 8E: NOISE MODELLING

8E.0.1 The following settings were used during the noise modelling.

8E.1 Modelling Assumptions

8E.1.1 The predicted operational noise levels have taken into account the worst-case scenario and have included the following assumptions:

- An internal level of 85 dB L_{Aeq} has been assumed within all buildings.
- External cladding to the EfW building will provide a low attenuation of 27 dB Rw;
- It has been assumed that louvres will be located at a high level and provide a low level of attenuation (11 dB Rw).
- 3 No. air inlets/outlets have been assumed on the top of the boiler house, emitting a sound power level of 97 dB Lw. Data has been sourced from similar facilities.
- 2 No. air inlet/outlet has been assumed on top of the turbine house, emitting a sound power level of 97 dB Lw. Data has been sourced from similar facilities.
- The final site ground levels will be 2 m AOD.
- Ramps will lead into and out of the fuel reception building, with the doors located at 5.5 m AOD.
- During all operational scenarios, doors into and doors out of the RDF reception building are assumed to be open at all times.
- The proposed 2 m high fence around the Site boundary has not been included in the noise model.

8E.2 Parameters

8E.2.1 Ground Absorption:

- Hard ground (0) for Site, Estuary, surrounding industrial areas
- Surrounding area: Soft ground (1) for all other areas

(Note: Acoustically Soft = 1, Acoustically Hard = 0)

8E.2.2 Proposed ground level:

- assumed to be 2 m AOD (the current ground level, assuming no land raising)

Receptor heights:

- 1.5 m for ground floor height, 4 m for first floor height.

Order of Reflections = 3

8E.2.3 Prediction methodology:

- ISO 9613 (1996) Acoustics - Attenuation of sound during propagation outdoors
- Calculation of Road Traffic Noise (CRTN), 1988

8E.3 Data Sources

8E.3.1 OS mapping: OS StreetView Raster 495030_657129. Purchased from Emapsite 15.08.2018.

8E.3.2 Scheme design: Fichtner Drawing , 2522-027-R6,

8E.3.3 Ground elevation data for wider area: environment.data.gov.uk/ds/survey#/

8E.3.4 Inputted Data

8E.3.5 Data on noise sources, cladding and louvres are given in Tables 8E.1 to 8E.3 and have been taken from similar schemes.

Table 8E.1: Internal reverberant noise levels

SPACE	WT.	SUM	OCTAVE BAND CENTRE FREQUENCY DB(A)							
			63Hz	125Hz	250Hz	500Hz	1kHz	2kHz	4kHz	8kHz
Fuel Reception Hall	dB(A)	85.0	54.3	65.3	70.8	75.2	79.4	79.6	78.4	72.3
Fuel Bunker	dB(A)	85.0	28.8	46.9	64.4	74.8	81.0	81.2	73.0	65.9
Boiler Hall	dB(A)	85.0	32.2	56.3	66.8	79.2	80.4	79.6	73.4	68.3
Ash Bunker	dB(A)	85.0	28.8	46.9	64.4	74.8	81.0	81.2	73.0	65.9
Flue Gas Treatment	dB(A)	85.0	51.5	65.7	70.1	75.5	80.8	80.0	75.8	69.7
Turbine Hall	dB(A)	85.0	25.8	50.9	62.4	72.8	77.0	82.2	78.0	71.9
Compressed Air	dB(A)	85.0	52.7	62.8	70.3	75.7	78.9	78.1	77.9	77.8
Water Treatment	dB(A)	85.0	61.4	73.5	76.0	81.4	78.6	74.8	69.6	60.5

Table 8E.2: External plant Sound Power Levels

PLANT ITEM	WT.	SOUND POWER LEVEL DB(A)	NO. OF UNITS IN NOISE MODEL	OCTAVE BAND CENTRE FREQUENCY DB(A)							
				63Hz	125Hz	250Hz	500Hz	1kHz	2kHz	4kHz	8kHz
ACC (per unit)	dB(A)	81.5	32 (16 lower fans, 16 upper fans)	56.6	61.6	68.1	80.4	71.9	68.6	62.1	52.0
Stack (per unit)	dB(A)	117.8	2	89.8	100.9	103.4	107.8	114.0	107.2	112.0	106.9
Air Inlet to boiler hall (per unit)	dB(A)	97.1	3	38.4	47.6	50.6	55.4	62.8	85.2	94.8	92.6
Air outlet from Turbine Hall (per unit)	dB(A)	97.1	2	38.4	47.6	50.6	55.4	62.8	85.2	94.8	92.6
One HGV Pass-By	dB(A)	104.3	-	87.8	90.9	96.4	98.8	98.0	97.2	91.0	84.9
34 HGV Pass-bys	dB(A)	119.6	-	103.1	106.2	111.7	114.1	113.3	112.5	106.3	100.2
36 HGV Pass-bys	dB(A)	119.8	-	103.3	106.4	111.9	114.3	113.5	112.7	106.5	100.4
43 HGV Pass-bys	dB(A)	120.6	-	104.1	107.2	112.7	115.1	114.3	113.5	107.3	101.2
44 HGV Pass-bys	dB(A)	120.7	-	104.2	107.3	112.8	115.2	114.4	113.6	107.4	101.3

Table 8E.3: Façade elements sound reduction index data

PLANT ITEM	WT.	RW	C	CTR	OCTAVE BAND CENTRE FREQUENCY								
					31Hz	63Hz	125Hz	250Hz	500Hz	1kHz	2kHz	4kHz	8kHz
Kingspan KS1000	dB	27	-1	-3	6	13	17	21	26	26	26	42	52
Roller Shutter Door (open)	dB	0	-1	-1	0	0	0	0	0	0	0	0	0
Louvres	dB	11	-1	-1	-	4	5	8	9	12	9	7	6

8E.4 Construction and Operational Road Traffic Data

8E.4.1 Road traffic data, including flow, speed and % HGV for both the construction and operational phases were provided from the transport assessment (refer to Chapter 9: Traffic and Transport), and are given in Tables 8E.4 and 8E.5.

Table 8E.4: Construction road traffic data

LINK REF.	LINK NAME	2021 BASE + COMMITTED NO CONSTRUCTION TRAFFIC		2021 BASE + COMMITTED WITH CONSTRUCTION TRAFFIC		WITH AND WITHOUT CONSTRUCTION TRAFFIC
		18 Hour AAWT	% HGV	18 Hour AAWT	% HGV	Speed (km/h)
1	South Marsh Road (East of Hobson Way)	977	28	1843	21	56
2	South Marsh Road (West of Hobson Way)	966	8	1041	7	55
3	Hobson Way	1945	32	2736	27	72
4	Kiln Lane	4756	34	5547	31	68
4	A1173 (West of North Moss Lane)	9660	30	10121	29	64
5	A1173 (North of A180)	18635	21	19419	20	97
6	A180 North of A1173	22553	31	23189	30	105
7	A180 South of A1173	32350	21	32498	21	108

Table 8E.5: Operational road traffic data

LINK REF.	LINK NAME	2023 BASE + COMMITTED NO OPERATIONAL TRAFFIC		2023 BASE + COMMITTED WITH OPERATIONAL TRAFFIC		WITH AND WITHOUT OPERATIONAL TRAFFIC
		18 Hour AAWT	%HG V	18 Hour AAWT	%HG V	Speed (km/h)
1	South Marsh Road (East of Hobson Way)	1003	28	1703	51	56
2	South Marsh Road (West of Hobson Way)	991	8	1043	7	55
3	Hobson Way	2045	31	2407	45	72
4	Kiln Lane	5083	36	5768	42	68
4	A1173 (West of North Moss Lane)	9875	31	10524	35	64
5	A1173 (North of A180)	19842	22	20488	24	97
6	A180 North of A1173	23567	31	23878	32	105
7	A180 South of A1173	33443	22	33776	22	108